

VOC Content Test Certificate

Thursday September 15th, 2011

Manufacturer: Ardex Australia (Unit 7, 20 Powers Rd, Seven Hills, NSW 2147)

Sample Description: ARDEX K 11

Date Tested: September 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 303-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168

Test Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p align="center">ARDEX K 11</p>
<p>One and two pack performance coatings for floors 140 grams per Litre as VOC content material</p>	<p>6.6 grams per Liter as VOC content per material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV110902