

# VOC Content Test Certificate

Friday May 30<sup>th</sup>, 2008

Manufacturer: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills NSW 2147)

Sample Description: Ardex WPM 320 bitumen emulsion waterproofing membrane

Date Tested: May 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b>  <b>Green Star Office Design V2 IEQ -13</b>  <b>Green Star Office Interiors V1.1 IEQ -11</b>	<b>Ardex WPM 320</b>
Architectural Sealant 250 grams per Litre	<b>45 grams per Litre</b>
<b>Specification</b>  <b>Green Building Council of Australia</b>  <b>Green Star Office Design V3 IEQ -13</b>	<b>Ardex WPM 320</b>
Architectural Sealant 250 grams per Litre	<b>45 grams per Litre</b>



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant

F0805-73