

VOC Content Test Certificate

Tuesday October 2nd, 2007

Manufacturer: Ardex Australia Pty Ltd

Unit 7, 20 Powers Road

Seven Hills NSW 2147

Sample Description: Ardex WPM 350 roof and deck waterproofing membrane

Date Tested: September 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

| | |
|--|-----------------------------------|
| <p>Specification</p> <p>Green Building Council of Australia</p> <p>Green Star Office Design V2 IEQ-13</p> <p>Green Star Office Interiors V1.1 IEQ-11</p> | <p>Ardex WPM 350</p> |
| <p>Architectural Sealant 250 grams per Litre maximum</p> | <p>102 grams per Litre</p> |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Project F0709-11