

# VOC Content Test Certificate

Tuesday 25<sup>th</sup> October 2022

**Supplier** Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills, NSW 2147, Australia).

**Sample Description** Ardex A38 22H12N

**Date Tested** October 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

**Test Method** ASTM D3960 & ASTM D2369 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred to in accordance with the laboratory testing guidance from the Green Building Council of Australia.

## Test Results

<b>Specification</b>  <b>Green Building Council of Australia</b>  <b>Green Star Design &amp; As Built V1.3-13.1.1B</b>  <b>Green Star Interiors V1.3-12.1.1B</b>	<b>Ardex A38 22H12N</b>
<b>General Purpose Adhesives and Sealants Limit:</b>  <b>50 grams per litre</b>	<b>2 grams per litre as VOC content per material</b>
<b>Meets GBCA VOC Content Requirement</b>	<b>Yes</b>



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant



Dr. Tuan Duong  
 PhD, BE (Chem. Eng.)  
 Senior Consultant



Travis Hale  
 BSc (Biotechnology)  
 Senior Consultant

**P22090047**